



## EC declaration of conformity

| For the following equipment:  |   |                               |              |                     |  |
|---|---|-------------------------------|--------------|---------------------|--|
| Product Name: Switching Power Supplies  |   |                               |              |                     |  |
| Model Designation: NDR-480-x (x=24,48)  |   |                               |              |                     |  |
| is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :  |   |                               |              |                     |  |
| RoHS Directive (2011/65/EU)   |   |                               |              |                     |  |
| Low Voltage Directive (2006/95/EC) :  |   |                               |              |                     |  |
| EN60950-1:2006+A11+A1+  | -A12+A2   | TUV certificate No: R50311049 |              |                     |  |
| Electromagnetic Compatibility Directive (2004/108/EC):  |   |                               |              |                     |  |
| EMI (Electro-Magnetic Interference)   |   |                               |              |                     |  |
| Conducted emission / Radia  | ated emission<br>EN55022:2010<br>EN55011:2009+A1:2010 (<br>EN61000-6-3:2007+A1:20<br>EN61204-3:2000               |                               |              | Class B<br>Class B  |  |
| Harmonic current  | EN61000-3-2:2014  |                               |              |                     |  |
| Voltage flicker   | EN61000-3-3:2013  |                               |              |                     |  |
| EMS (Electro-Magnetic Susceptibility)   |   |                               |              |                     |  |
| EN55024:2010 EN61204-   | -3:2000 EN61000-6-2:200   | 5                             |              |                     |  |
| ESD air   | EN61000-4-2:2009  |                               | Level 4      | 15KV                |  |
| ESD contact   | EN61000-4-2:2009  |                               | Level 4      | 8KV                 |  |
| RF field susceptibility   | EN61000-4-3:2006+A1:20  | 008+A2:2010                   | Level 3      | 10V/m               |  |
| EFT bursts  | EN61000-4-4:2012  |                               | Level 3      | 2KV/5KHz            |  |
| Surge susceptibility  | EN61000-4-5:2006  |                               | Level 3      | 2KV/Line-Line       |  |
| Surge susceptibility  | EN61000-4-5:2006  |                               | Level 4      | 4KV/Line-FG         |  |
| Conducted susceptibility  | EN61000-4-6:2014  |                               | Level 3      | 10V                 |  |
| Magnetic field immunity   | EN61000-4-8:2010  |                               | Level 4      | 30A/m               |  |
| Voltage dip, interruption   | oltage dip, interruption EN61000-4-11:2004 >95% dip 0.5 periods 30% dip 25 periods >95% interruptions 250 periods |                               |              |                     |  |
| Note:  The power supply is considered as a component that will be operated in combination with final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.  For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File). |   |                               |              |                     |  |
| This Declaration is effective from serial number EB5xxxxxxx   |   |                               |              |                     |  |
| Person responsible for marking this declaration:  |   |                               |              |                     |  |
| Mean Well Enterprises Co., Ltd.  (Manufacturer Name)  |   |                               |              |                     |  |
| No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 248, Taiwan (Manufacturer Address)   |   |                               |              |                     |  |
| Johnny Huang/Senior Verification  | Engineer: Tohunn  | Ted Cher                      | ng/Product l | Manager: Pell Chang |  |
| (Name / Position)   | (Signature)   | (Name / P                     | -            | (Signature)         |  |
| Taiwan  | July 16th, 2015   |                               |              | 7                   |  |
| (Place)   | (Date)  |                               |              |                     |  |